

Subject: RE: Data projector image in CSC-12

Date: Wed, 05 Sep 2001 13:05:22 -0400

From: "Gyurisin, Ed" <gyurisin@CIDDE.PITT.EDU>

To: "Joseph J. Grabowski" <joeg@pitt.edu>

Joe,

The image from permanent projector can be lower. The permanent projector will be installed inverted. This allows us to take advantage of the 30% off axis lens configuration (typical) maintaining reasonably good geometry.

Ed Gyurisin

-----Original Message-----

From: Joseph J. Grabowski [<mailto:joeg+@pitt.edu>]

Sent: Friday, August 31, 2001 5:18 PM

To: Gyurisin, Ed

Subject: Data projector image in CSC-12

Ed:

When you get a chance, or at least for the permanent data projector installation, can you please think about lowering the projected image on the bulkhead as low as possible - to just above the fire alarm? I'm hoping that projecting ontop of the access panels won't be a problem; the trade off is the imperfect image on top of the access panel versus a higher up image. I'd like to see what a lower image buys me vs what it costs me.

thanks,
Joe G.

--

Joseph J. Grabowski
Associate Professor, Department of Chemistry
University of Pittsburgh
Pittsburgh, PA 15260

Home Page: <http://www.pitt.edu/~joeg>

Phone: 412-624-8632

Fax: 412-624-8611

Behold the turtle. He makes progress only when he sticks his neck out.

-- James Bryant Conant